

ENERGY STAR[®] for New Homes

COMPLIANCE REPORT



Building Information	Builder
<p>2130 westside Park INVERMERE, BC VOA</p> <p>Multi-Unit Residential: No</p> <p>Attached or Detached: Detached</p> <p>Enrolment Date: Jun 5, 2018</p> <p>ES Enrolment ID: 66ES000091</p>	<p>Meredith Hamstead/Paul Denchuk dba thinkBright Environmental Innovations</p> <p>ID: C7411</p> <p>T: 250-688-1150</p> <p>E: m.hamstead@thinkbright.ca</p>
ENERGY STAR [®] for New Homes Standard Information	Energy Advisor
<p>ESNH Standard Version: 12.7</p> <p>Evaluation Date: Jun 1, 2018</p> <p>Submission Date: Jun 18, 2018</p> <p>Compliance Method: Performance</p> <p>ESNH Zone: Zone 3 (4000 - 4999)</p>	<p>Sereda, Nate</p> <p>ID: 6618</p> <p>T: 250-342-5156</p> <p>E: nate@energyadvise.ca</p>
	Service Organization
	<p>DW Energy Advisors Inc.</p> <p>ID: 66</p> <p>T: 604-465-1822</p> <p>E: wgalaugher@shaw.ca</p>

The ENERGY STAR name and symbol are registered trademarks of the United States Environmental Protection Agency and are used with permission.



Natural Resources
Canada

Ressources naturelles
Canada

Canada

ENERGY STAR[®] for New Homes

COMPLIANCE REPORT



12.7 ENERGY STAR[®] for New Homes Minimum Requirements (Targeted)

EnerGuide Rating

Target: 81
Actual: 85

Building Assemblies

Ceilings below attic	RSI 8.67 (R 49.2)
Walls above grade	RSI 3.08 (R 17.5)
Foundation walls below or in contact with the ground	RSI 2.98 (R 16.9)
Floors over unheated spaces	RSI 4.67 (R 26.5)

The thermal resistance requirements are listed in effective values, unless indicated with "(nominal)" for nominal values.

Airtightness

Method (ACH, NLA, NLR): Air changes per hour (ACH)
Target: Level 4 ACH: 1.0, NLA: 0.49 cm²/m², NLR: 0.38 L/s/m²

Electrical Savings Options

75% of the entire house
ENERGY STAR certified clothes washer
ENERGY STAR certified dishwasher
ENERGY STAR certified refrigerator
ENERGY STAR certified bathroom fan 10 to 89 cfm
HRV/ERV fan Efficacy: SRE <75% @0 °C ≥0.57 L/s/W (1.2 cfm/W)
Total: 505 kWh/yr

NOTE: Values shown are targeted minimum values only, higher performance measures may have been implemented.

The ENERGY STAR name and symbol are registered trademarks of the United States Environmental Protection Agency and are used with permission.